



SHI PRODUCT PASSPORT

Find products. Certify buildings.

SHI Product Passport No.:

1275-10-1018

Roth PPSU PressCheck

Product group: Heating - Pipe systems / Fittings - Pipes / pipe cladding



Roth Werke GmbH
Am Seerain 2
35232 Dautphetal-Buchenau



Product qualities:










Köttner

Helmut Köttner
Scientific Director
Freiburg, 11 May 2026



Contents

 SHI Product Assessment 2024	1
 QNG - Qualitätssiegel Nachhaltiges Gebäude	2
 DGNB New Construction 2023	3
 DGNB New Construction 2018	5
 BNB-BN Neubau V2015	6
 BREEAM DE Neubau 2018	7
 LEED v4.1	8
Product labels	9
Legal notices	10
Technical data sheet/attachments	10

The SHI Database is the first and only database for construction products whose comprehensive processes and data accuracy are regularly verified by the independent auditing company SGS-TÜV Saar





Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



SHI Product Assessment 2024

Since 2008, Sentinel Holding Institut GmbH (SHI) has been establishing a unique standard for products that support healthy indoor air. Experts carry out independent product assessments based on clear and transparent criteria. In addition, the independent testing company SGS regularly audits the processes and data accuracy.

Criteria	Product category	Assessment
SHI Product Assessment		Indoor air neutral



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



QNG - Qualitätssiegel Nachhaltiges Gebäude

The Qualitätssiegel Nachhaltiges Gebäude (Quality Seal for Sustainable Buildings), developed by the German Federal Ministry for Housing, Urban Development and Building (BMWSB), defines requirements for the ecological, socio-cultural, and economic quality of buildings. The Sentinel Holding Institut evaluates construction products in accordance with QNG requirements for certification and awards the QNG ready label. Compliance with the QNG standard is a prerequisite for eligibility for the KfW funding programme. For certain product groups, the QNG currently has no specific requirements defined. Although classified as not assessment-relevant, these products remain suitable for QNG-certified projects.

Criteria	Pos. / product group	Considered substances	QNG assessment
3.1.3 Schadstoffvermeidung in Baumaterialien			QNG ready - Not relevant for assessment



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



DGNB New Construction 2023

The DGNB System (German Sustainable Building Council) assesses the sustainability of various types of buildings. It can be applied to both large-scale private and commercial projects as well as smaller residential buildings. The 2023 version sets high standards for ecological, economic, socio-cultural, and functional aspects throughout the entire life cycle of a building.

Criteria	Assessment
ECO1.1 Life cycle cost (*)	May positively contribute to the overall building score

Criteria	Assessment
SOC2.1 Barrier-free design (*)	May positively contribute to the overall building score

Criteria	Assessment
ENV2.2 Potable water demand and waste water volume (*)	May positively contribute to the overall building score

Criteria	No. / Relevant building components / construction materials / surfaces	Considered substances / aspects	Quality level
ENV 1.2 Local environmental impact, 03.05.2024 (3rd edition)			Not relevant for assessment



Criteria	No. / Relevant building components / construction materials / surfaces	Considered substances / aspects	Quality level
ENV 1.2 Local environmental impact, 29.05.2025 (4th edition)			Not relevant for assessment



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



DGNB New Construction 2018

The DGNB System (German Sustainable Building Council) assesses the sustainability of various types of buildings. It can be applied to both large-scale private and commercial projects as well as smaller residential buildings.

Criteria	No. / Relevant building components / construction materials / surfaces	Considered substances / aspects	Quality level
ENV 1.2 Local environmental impact			Not relevant for assessment



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



BNB-BN Neubau V2015

The Bewertungssystem Nachhaltiges Bauen (Assessment System for Sustainable Building) is a tool for evaluating public office and administrative buildings, educational facilities, laboratory buildings, and outdoor areas in Germany. The BNB was developed by the former Federal Ministry for the Environment, Nature Conservation, Building and Nuclear Safety (BMUB) and is now overseen by the Federal Ministry for Housing, Urban Development and Building (BMWSB).

Criteria	Pos. / product type	Considered substance group	Quality level
1.1.6 Risiken für die lokale Umwelt			Not relevant for assessment



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



BREEAM DE Neubau 2018

BREEAM (Building Research Establishment Environmental Assessment Methodology) is a UK-based building assessment system that evaluates the sustainability of new constructions, refurbishments, and conversions. Developed by the Building Research Establishment (BRE), the system aims to assess and improve the environmental, economic, and social performance of buildings.

Criteria	Product category	Considered substances	Quality level
Hea 02 Indoor Air Quality			Not relevant for assessment



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



LEED v4.1

LEED (Leadership in Energy and Environmental Design) is an internationally recognised building certification system developed by the U.S. Green Building Council. It is one of the most widely used sustainability standards for buildings worldwide and is particularly applied in internationally oriented projects. LEED assesses buildings holistically across categories such as energy efficiency, resource conservation, material selection, indoor environmental quality and site sustainability. Depending on the number of points achieved, projects are awarded one of the certification levels: LEED Certified, Silver, Gold or Platinum.

Criteria	Product category	Considered substances	Assessment
EQ Credit: Low-Emitting Materials			Not relevant for assessment



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



Product labels

In the construction industry, high-quality materials are crucial for a building's indoor air quality and sustainability. Product labels and certificates offer guidance to meet these requirements. However, the evaluation criteria of these labels vary, and it is important to carefully assess them to ensure products align with the specific needs of a construction project.



Products bearing the Sentinel Holding Institute QNG-ready seal are suitable for projects aiming to achieve the "Qualitätssiegel Nachhaltiges Gebäude" (Quality Seal for Sustainable Buildings). QNG-ready products meet the requirements of QNG Appendix Document 3.1.3, "Avoidance of Harmful Substances in Building Materials." The KfW loan program Climate-Friendly New Construction with QNG may allow for additional funding.



Product:

Roth PPSU PressCheck

SHI Product Passport no.:

1275-10-1018



Legal notices

(*) These criteria apply to the construction project as a whole. While individual products can positively contribute to the overall building score through proper planning, the evaluation is always conducted at the building level. The information was provided entirely by the manufacturer.

Find our criteria here: <https://www.sentinel-holding.eu/de/Themenwelten/Pr%C3%BCfverfahren/Pr%C3%BCfverfahren%20f%C3%BCr%20Produkte>

The SHI Database is the first and only database for construction products whose comprehensive processes and data accuracy are regularly verified by the independent auditing company SGS-TÜV Saar



Publisher

Sentinel Holding Institut GmbH
Bötzingen Str. 38
79111 Freiburg im Breisgau
Germany
Tel.: +49 761 590 481-70
info@sentinel-holding.eu
www.sentinel-holding.eu

■ Beschreibung

Die Roth PressCheck®-Fittings werden zur Herstellung von unlösbaren, kraftschlüssigen und dauerhaft dichten Verbindungen mit allen Roth Systemrohren verwendet.

Die Grundkörper der Roth PressCheck® PPSU-Fittings bestehen aus dem Hochleistungskunststoff Polyphenylsulfon (PPSU) sowie einer Presshülse aus Edelstahl. Die Konstruktion des Fittings wurde für hohe mechanische und thermische Belastungen (Auszugskräfte, Torsionskräfte, Scherkräfte und Schubkräfte) ausgelegt. Für die Dichtigkeit sorgen 2 O-Ringe aus EPDM. Die Anzahl sowie die Auslegung der O-Ringe tragen zu einer hohen Betriebssicherheit bei.

Die Kunststoff-Fittings sind korrosionsbeständig und aufgrund des inneren Aufbaus sowie seiner glatten Oberfläche inkrustationsfrei. Resultierend daraus wird die Bildung und Ablagerung von Biofilmen wirksam vermindert.

Für eine sichere Montage sind die patentierten Roth PressCheck®-Fittings mit einer definierten Leckage im unverpressten Zustand ausgestattet. Eine beidseitige Pressbackenführung sorgt für eine konstante und einwandfreie Qualität der Verpressung.




■ Werkstoffeigenschaften

- > Polyphenylsulfon (PPSU) ist ein Hochleistungskunststoff mit besten mechanischen Eigenschaften bei Zugfestigkeit, Bruchdehnung, Steifigkeit, Kerbschlagzähigkeit und Wärmeformbeständigkeit.
- > Darüber hinaus besitzt PPSU eine ausgezeichnete Heißwasserbeständigkeit und ist unempfindlich gegen Spannungsrisse, hohe Druckbeanspruchung und Temperaturen (Dauergebrauchstemperaturen bis 180 °C).
- > Der Werkstoff ist hygienisch unbedenklich und für jede Trinkwasserqualität, entsprechend den Vorgaben und Grenzwerten der Trinkwasserverordnung, geeignet.
- > Bei Verwendung von Inhibitoren und Frostschutzmitteln in Heizungsinstallationen sowie im Einsatz mit chloriertem Trinkwasser weist das Material eine ausgezeichnete chemische Beständigkeit auf.
- > Die Presshülse besteht aus einem Chrom-Nickel-Stahl, der eine hohe Korrosionsbeständigkeit sowie gute mechanische Eigenschaften aufweist. Der Werkstoff lässt sich ausgezeichnet kaltverformen und besitzt eine gute Formbeständigkeit.
- > Die Dichtelemente sind aus einem hochwertigen EPDM gefertigt und besitzen eine gute Alterungsbeständigkeit unter thermischer Belastung. Das Material ist sehr elastisch und stark verformbar, wodurch eine sehr gute Dichtwirkung erzielt wird.
- > Die Chemikalienbeständigkeit ist gut.


■ Abmessungen

Kupplung




Mat.-Nr.	Ø Dimension [mm]	D [mm]	L [mm]	Z [mm]
1115005548	14	14	66	18
1115005549	17	17	66	18
1115005550	20	20	66	18
1115005551	25	26	66	18
1115005552	32	32	66	18
1135004462	40	40	91	29
1135004463	50	50	91	29

Kupplung reduziert




Mat.-Nr.	Ø Dimension [mm]	D1 [mm]	D2 [mm]	L [mm]	Z [mm]
1115005553	17 x 14	17	14	66	18
1115005554	20 x 14	20	14	66	18
1115005555	20 x 17	20	17	66	18
1135004465	25 x 17	26	17	66	18
1115005556	25 x 20	32	20	66	18
1135004466	32 x 20	40	20	66	18
1115005557	32 x 25	50	25	66	18
1135004467	40 x 32	40	32	82	20
1135004468	50 x 40	50	40	91	29

Winkel 90°




Mat.-Nr.	Ø Dimension [mm]	D [mm]	L [mm]	A [mm]	Z [mm]
1115005558	14	14	47	37	13
1115005559	17	17	50	38	14
1115005560	20	20	53	40	16
1115005561	25	26	59	43	19
1115005562	32	32	65	46	22
1135004469	40	40	85	61	30
1135004470	50	50	95	65	34

Winkel 45°




Mat.-Nr.	Ø Dimension [mm]	D [mm]	L [mm]	B [mm]	A [mm]	Z [mm]
1115005563	25	26	70	52	35	12
1115005564	32	32	73	57	35	12
1135004471	40	40	100	74	49	19

T-Stück



Mat.-Nr.	Ø Dimension [mm]	D [mm]	L [mm]	B [mm]	A [mm]	Z [mm]
1115005523	14	14	73	47	37	13
1115005524	17	17	76	50	38	14
1115005525	20	20	79	53	40	16
1115005526	25	26	85	59	43	19
1115005527	32	32	91	65	46	22
1135004450	40	40	121	85	61	30
1135004452	50	50	130	95	65	34

T-Stück Abgänge reduziert



Mat.-Nr.	Ø Dimension [mm]	D1 [mm]	D2 [mm]	D3 [mm]	L [mm]	B [mm]	A1 [mm]	A2 [mm]	A3 [mm]	Z1 [mm]	Z2 [mm]	Z3 [mm]
1115005528	17 x 14 x 17	17	14	17	73	50	37	38	37	13	14	13
1115005529	20 x 14 x 20	20	14	20	73	53	37	40	37	13	16	13
1115005530	20 x 17 x 20	20	17	20	76	53	38	40	38	14	16	14
1115005531	25 x 17 x 25	25	17	25	76	58	38	43	38	14	19	14
1115005532	25 x 20 x 25	25	20	25	79	58	40	43	40	16	19	16
1115006924	32 x 17 x 32	32	17	32	77	65	39	46	39	15	22	15
1115005533	32 x 20 x 32	32	20	32	79	65	40	46	40	16	22	16
1115005534	32 x 25 x 32	32	25	32	85	65	43	56	43	19	22	19
1135004454	40 x 20 x 40	40	20	40	102	75	51	51	51	20	27	20
1135004455	40 x 25 x 40	40	25	40	108	75	54	51	54	23	27	23
1135004456	40 x 32 x 40	40	32	40	114	75	57	51	57	26	27	26
1135004457	50 x 40 x 50	50	40	50	122	96	61	66	61	30	35	30
1115007433	17 x 17 x 14	17	17	14	76	50	38	38	38	14	14	14
1115005535	20 x 20 x 17	20	20	17	79	53	40	40	40	16	16	16
1115005536	25 x 25 x 20	25	25	20	85	58	43	43	43	19	19	19
1115005537	17 x 14 x 14	17	14	14	75	50	38	38	38	14	14	14
1115005538	20 x 17 x 17	20	17	17	76	53	38	40	38	14	16	14
1115005539	25 x 17 x 17	25	17	17	79	58	40	43	40	16	19	16
1115005540	25 x 17 x 20	25	17	20	79	58	40	43	40	16	19	16
1115005541	25 x 20 x 20	25	20	20	80	58	40	43	40	16	19	16
1135004460	32 x 20 x 20	32	20	20	82	65	41	46	41	17	22	17
1135004461	32 x 20 x 25	32	20	25	81	65	41	46	41	17	22	17
1115005542	32 x 25 x 25	32	25	25	85	65	43	46	43	19	22	19
1115005543	17 x 20 x 17	17	20	17	79	50	40	38	40	16	14	16
1115005544	20 x 25 x 17	20	25	17	85	53	43	40	43	19	16	19
1115005545	20 x 25 x 20	20	25	20	85	53	43	40	43	19	16	19
1115005546	20 x 32 x 20	20	32	20	91	53	46	40	46	22	16	22
1115005547	25 x 32 x 25	25	32	25	91	58	46	43	46	22	19	22

■ Technische Daten

Einsatzbereich	Trinkwasser-Installationen Heizungs-Installationen
Werkstoff	Grundkörper: Polyphenylsulfon (PPSU) Presshülse: austenitischer Chrom-Nickel Stahl Dichtelemente: EPDM
Farbe	grau
Baustoffklasse	B1 nach DIN 4102 E nach EN 13501
max. Temperatur dauerhaft	70 °C / 10 bar
max. Temperatur kurzzeitig	95 °C / 6 bar
max. Druck	10 bar
Besonderheit	unverpresst undicht bei 1,5 bar Einprägung des Produktionszeitraums
Prüf- und Zertifizierungsgrundlagen	DVGW W 542 DVGW W 534 DVGW W 270 UBA KTW EN ISO 21003
Zulassungsnummer	DVGW DW-8501BR0037
verwendbare Roth Systemrohre	Alu-Laserplus X-PERT S5 PERTEX S5 DUOPEX S5 Alu Laserflex

Anmerkung: Die jeweils gültigen Herstellerangaben/Montagevorschriften für die Systemlösungen sind zu beachten.



DVGW-Baumusterprüfzertifikat

DVGW type examination certificate

DW-8501BR0037
Registriernummer
registration number

Anwendungsbereich <i>field of application</i>	Produkte der Wasserversorgung <i>products of water supply</i>
Zertifikatinhaber <i>owner of certificate</i>	ROTH WERKE GmbH Am Seerain 2, D-35232 Dautphetal
Vertreiber <i>distributor</i>	ROTH WERKE GmbH Am Seerain 2, D-35232 Dautphetal
Produktart <i>product category</i>	Installationssysteme und Systemverbinder (PN 10): Trinkwasserinstallationssystem (8501)
Produktbezeichnung <i>product description</i>	Trinkwasserinstallationssystem bestehend aus Pressverbindern aus Metall oder Kunststoff (PPSU) und Verbundrohr (PE-RT/Al/PE-RT)
Modell <i>model</i>	Roth Rohr-Installationssystem mit Systemrohr Alu-Laserplus
Prüfberichte <i>test reports</i>	Kontrollprüfung Labor: V058/25.3 vom 23.04.2025 (IMA) Ergänzungsprüfung: V239/19 vom 06.08.2019 (IMA) Ergänzungsprüfung: V386/18 vom 27.12.2018 (IMA) Baumusterprüfung: 22 0002404-3 vom 18.02.2003 (IMA) Baumusterprüfung: 22 0002404-1/ -2 vom 16.02.2003 (IMA)
Prüfgrundlagen <i>test basis</i>	DVGW CERT ZP 8500 (23.05.2022) DVGW W 534-(P) (01.07.2015)
Ablaufdatum / AZ <i>date of expiry / file no.</i>	20.02.2027 / 26-0004-WNV

70028-04-A-DE

08.01.2026 Gre A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvwg-cert.com

Typ type	Technische Daten technical data	Bemerkungen remarks
Roth Rohr-Installationssystem	Nenndurchmesser: 14 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 16 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 17 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 20 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 25 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 32 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 40 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 50 mm	Typ M-MV, Typ M-KV
Roth Rohr-Installationssystem	Nenndurchmesser: 63 mm	Typ M-MV

Verwendungshinweise / Bemerkungen

hints of utilization / remarks

zu verwendende Pressverbinder:

Metall, Typ: M-MV

Hersteller: Gebr. Kemper GmbH + Co. KG, D-Olpe,
BENDER Armaturen GmbH & Co. KG, D-Lennestadt,
Bruse GmbH, D-Suhl-Albrechts

Kunststoff (PPSU), Typ: M-KV

Hersteller: Roth Werke GmbH, Dautphetal

zu verwendendes Verbundrohr:

Systemrohr Alu-Laserplus, Roth Werke GmbH, Dautphetal, DVGW Registriernummer: DW-8236BP5589

Die trinkwasserhygienische Eignung ist mit „Konformitätsbestätigung Hygiene“ gem. der aktuell gültigen Rechtsgrundlage nachgewiesen.





Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberttring 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Akkreditiert durch das Bundesministerium
für Digitalisierung und Wirtschaftsstandort



ÖVGW-Zertifikat

über die Verleihung des Rechtes
zur Führung der ÖVGW-Qualitätsmarke Wasser

Registrierungsnummer

W 1.433

Geltungsdauer

bis Ende November 2024

Inhaber

Roth Werke GmbH

Am Seerain
35232 Dautphetal
DEUTSCHLAND

◆ Vertrieb in Österreich

Roth Austria Vertriebsniederlassung
Dinstlstraße 4
3500 Krems

Hersteller

System & Verbinder: Roth Werke GmbH / DE
Rohre: Becker Plastics GmbH / DE

Prüfungsart

Verlängerungsprüfung

Prüfbericht

TGM – VA KU 29222/1 vom 12. Januar 2022

Qualitätsstandards/Prüfrichtlinien

• QS-W 301 Ausgabe Mai 2020

Produkt

Roth Trinkwasser – System

Mehrschichtverbund-Rohre M mit weißem
Außenmantel PE-RT Typ II/Al/PE-RT Typ II

in den Dimensionen:

(14x2,0), (17x2,0), (20x2,0), (26x3,0), (32x3,0),
(40x3,5), (50x4,0) und (63x4,5) mm

(Anwendungsklassen 1, 2 / p_D = 10 bar)

Pressverbinder aus Messing oder PPSU

Weitere Angaben siehe Seite 2

ZVR 818158001

Die Verleihung erfolgt unter Zugrundelegung der Allgemeinen Geschäftsbedingungen GW 30 ÖVGW-Qualitätsmarke Produkte Gas & Wasser „Voraussetzungen für die Zuerkennung der ÖVGW-Qualitätsmarke für Produkte der Gas- und Wasserversorgung.“

Wien, am 27. Jänner 2022

Dipl.-Ing. (FH) Alexander Schwanzer
Leiter der ÖVGW-Zertifizierungsstelle

Produkt (Fortsetzung)

Pressverbinder aus PPSU:

T-Stück

T-Stück im Abgang reduziert

T-Stück im Durchgang reduziert

T-Stück im Abgang und Durchgang reduziert

T-Stück im Abgang erweitert

Kupplung

Kupplung reduziert

Winkel 90°

Winkel 45°

Dimensionen (mm):

14x14x14, 17x17x17, 20x20x20, 25x25x25,
32x32x32, 40x40x40, 50x50x50

17x14x17, 20x14x20, 20x17x20, 25x17x25,
25x20x25, 32x17x32, 32x20x32, 32x25x32,
40x20x40, 40x25x40, 40x32x40, 50x40x50

17x17x14, 20x20x17, 25x25x20

17x14x14, 20x17x17, 25x17x17, 25x17x20,
25x20x20, 32x20x20, 32x20x25, 32x25x25

17x20x17, 20x25x17, 20x25x20, 20x32x20,
25x32x25

14x14, 17x17, 20x20, 25x25, 32x32, 40x40, 50x50

17x14, 20x14, 20x17, 25x17, 25x20, 32x20, 32x25,
40x32, 50x40

14x14, 17x17, 20x20, 25x25, 32x32, 40x40, 50x50

25x25, 32x32, 40x40

Pressverbinder aus Messing:

T-Stück

T-Stück im Abgang reduziert

T-Stück im Abgang und Durchgang reduziert

Kupplung

Kupplung reduziert

Winkel 90°

Winkel 45°

Übergangsmuffe mit IG

Übergangsnippel mit AG

Übergangswinkel mit IG

Übergangswinkel mit AG

Wandscheibe mit IG

U-Wandscheibe mit IG

Thermoentkoppler mit IG

Übergangsstück Meplafix mit IG

Übergangswinkel Meplafix mit IG

Durchgangs-T-Stück Meplafix mit IG

Wandscheibenset Typ A/SE (153) mit IG

Wandscheibenset Typ I/SE (153) mit IG

Wandscheibenset Typ I/SE (80) mit IG

U-Wandscheibenset Typ A/SE (153) mit IG

U-Wandscheibenset Typ I/SE (153) mit IG

Dimensionen (mm):

63x63x63

50x20x50, 50x25x50, 50x32x50, 63x25x63,

63x32x63, 63x40x63, 63x50x63

40x32x32, 63x50x50

63x63

40x25, 50x32, 63x40, 63x50

63x63

50x50, 63x63

14x $\frac{1}{2}$ ", 17x $\frac{1}{2}$ ", 17x $\frac{3}{4}$ ", 20x $\frac{1}{2}$ ", 20x $\frac{3}{4}$ ", 25x $\frac{3}{4}$ ", 25x1",
32x1", 32x1 $\frac{1}{4}$ ", 40x1 $\frac{1}{4}$ ", 40x1 $\frac{1}{2}$ ", 50x1 $\frac{1}{2}$ ", 63x2"

14x $\frac{1}{2}$ ", 14x $\frac{3}{4}$ ", 17x $\frac{1}{2}$ ", 17x $\frac{3}{4}$ ", 20x $\frac{1}{2}$ ", 20x $\frac{3}{4}$ ", 25x $\frac{3}{4}$ ",
25x1", 32x1", 32x1 $\frac{1}{4}$ ", 40x1 $\frac{1}{4}$ ", 50x1 $\frac{1}{2}$ ", 63x2"

17x $\frac{1}{2}$ ", 17x $\frac{3}{4}$ ", 20x $\frac{1}{2}$ ", 20x $\frac{3}{4}$ ", 25x $\frac{3}{4}$ ", 25x1", 32x1",
32x1 $\frac{1}{4}$ ", 40x1 $\frac{1}{2}$ ", 50x1 $\frac{1}{2}$ "

14x $\frac{1}{2}$ ", 17x $\frac{1}{2}$ ", 17x $\frac{3}{4}$ ", 20x $\frac{1}{2}$ ", 20x $\frac{3}{4}$ ", 25x $\frac{3}{4}$ ", 25x1",
32x1", 32x1 $\frac{1}{4}$ ", 40x1 $\frac{1}{4}$ ", 50x1 $\frac{1}{2}$ "

14x $\frac{1}{2}$ ", 17x $\frac{1}{2}$ ", 20x $\frac{1}{2}$ ", 20x $\frac{3}{4}$ ", 25x $\frac{3}{4}$ "

17x $\frac{1}{2}$ "x17, 17x2 $\frac{1}{2}$ "x20, 20x $\frac{1}{2}$ "x17, 20x $\frac{1}{2}$ "x20

17-20

17x $\frac{1}{2}$ "

17x $\frac{1}{2}$ "

17x $\frac{1}{2}$ "x17

17x $\frac{1}{2}$ ", 20x $\frac{1}{2}$ "

17x $\frac{1}{2}$ ", 20x $\frac{1}{2}$ "

17x $\frac{1}{2}$ "

17x $\frac{1}{2}$ "x17, 20x $\frac{1}{2}$ "x20

17x $\frac{1}{2}$ "x17, 20x $\frac{1}{2}$ "x20





Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberting 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at




Akkreditiert durch das Bundesministerium
für Digitalisierung und Wirtschaftsstandort



Produkt (Fortsetzung)

T-Stück mit IG	17x $\frac{1}{2}$ "x17, 17x $\frac{3}{4}$ "x17, 20x $\frac{1}{2}$ "x20, 20x $\frac{3}{4}$ "x20, 25x $\frac{1}{2}$ "x25, 25x $\frac{3}{4}$ "x25, 32x $\frac{1}{2}$ "x32, 32x $\frac{3}{4}$ "x32, 40x $\frac{3}{4}$ "x40, 40x1"x40, 50x1"x50, 63x1"x63
Anschlusswinkel mit IG/AG	17x $\frac{1}{2}$ "($\frac{3}{4}$ "AG)
Geräteverschraubungen mit AG	20x $\frac{3}{4}$ ", 20x1", 25x1", 32x1", 32x1 $\frac{1}{4}$ "
Geräteverschraubungen mit IG	20x $\frac{3}{4}$ ", 20x1", 25x1", 32x1", 32x1 $\frac{1}{4}$ "
Pressverschraubungen	14, 17, 20
Anschlussverschraubungen mit IG	17x $\frac{1}{2}$ ", 17x $\frac{3}{4}$ ", 20x $\frac{3}{4}$ ", 20x1", 25x $\frac{3}{4}$ ", 25x1", 32x $\frac{3}{4}$ ", 32x1", 32x1 $\frac{1}{4}$ ", 40x1 $\frac{1}{2}$ "


Dipl.-Ing (FH) Alexander Schwanzer
Leiter der ÖVGW-Zertifizierungsstelle



Technical-approval-with-product certificate K43968/06

Issued 2021-08-15

Replaces K43968/05

Page 1 of 3

Roth Werke System

STATEMENT BY KIWA

With this technical approval-with-product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Roth Werke GmbH

As specified in this technical approval-with-product certificate and marked with the Kiwa®-mark in the manner as indicated in this technical approval-with-product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 G "Plastics piping systems of PE-RT/Al intended for transport of hot and cold drinking water" dated 15-12-2011, inclusive amendment sheet dated 13-03-2018."

Within the framework of this technical approval-with-product certificate Kiwa does not impose any inspections with regard to the production of other parts of the plastics piping system, nor the manufacturing of the plastics piping system itself.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

283171015

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
Roth Werke GmbH
Am Seerain
35232 DAUTPHETAL-BUCHENAU
Germany
Tel. 06466 / 922 0
service@roth-werke.de
www.roth-werke.de



Roth Werke System

PRODUCT SPECIFICATION

Plastics piping systems of PE-RT/Al intended for the transport of cold and heated drinking water according to BRL-K536 part G

The system consists of:

- PE-RT/Al/PE-RT pipes manufactured by Becker Plastics (certificate K44813);
- PPSU press fittings (dimensions 16 to 50 mm) manufactured by Roth Werke GmbH (certificate K43967);
- Metal press fittings manufactured by Roth Werke GmbH (certificate K67757).

The pipe dimensions as indicated in the table below belong to this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)	Wall thickness aluminum layer (mm)
16	2.0	0.2
17	2.0	0.2
20	2.0	0.2
26	3.0	0.4
32	3.0	0.4
40	3.5	0.6
50	4.0	0.6
63	4.5	0.8

Color pipes : inside naturel, outside white or silver

Color PPSU fittings : grey

Color metal fittings : brass

Press profile: Special Roth press profile

Fitness for contact with drinking water



The pipes and fittings used in this system are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

MARKING

The products are marked with the Kiwa-mark.

Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  * + Class 2 / 10 bar;
- the manufacturer's name, trade name, system name, logo or certificate number of accompanying technical approval (system)certificate;
- material identification: PE-RT type 2;
- the buildup of the pipe: PE-RT/Al/PE-RT;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

Location of the marks: on every pipe at intervals of not more than 2 m.





The realization of the marks is as follows: clear durable and indelible.

*) for smaller diameters permitted by Kiwa.

Roth Werke System

Fittings


The minimum required marking on the fittings shall be:

- **KIWA**  or on small products  or  or **KK** * or **KK** * (if not possible **KIWA**  only on the smallest packaging unit)**;
- manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe in mm;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clear, durable and indelible.

The smallest packaging unit of the fittings are provided with at least the following information:

- **KIWA** ;
- manufacturer's name, trade name, system name, logo or certificate number of the accompanying technical approval (system) certificate, in accordance with the marking of the connecting pipe;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm;
- material identification in case the fitting body is made of plastics.

Location of the marks: on every package.

The realization of the marks is as follows: clear, durable and indelible.

*) for small fittings marking with only KK is permitted

***) only after approval by Kiwa

LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The piping system is intended to be used for the transport of cold and hot drinking water according to a temperature profile class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar.

RECOMMENDATIONS FOR CUSTOMERS


Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Roth Werke GmbH
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.



Product certificate K43967/06

Issued 2021-08-15

Replaces K43967/05

Page 1 of 3

PPSU Fittings

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Roth Werke GmbH

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL- K536 G "Plastics piping systems of PE-RT/Al intended for transport of hot and cold drinking water" dated 15-12-2011 inclusive amendment sheet dated 13-03-2018.

Ron Scheepers
Kiwa

*This product certificate is only valid in combination with a Kiwa certified plastics piping system.
Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.*

CERTIFICATE

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
Roth Werke GmbH
Am Seerain
35232 DAUTPHETAL-BUCHENAU
Germany
Tel. +49 (0)06466 / 922 0
service@roth-werke.de
www.roth-werke.de



Certification process
consists of initial and
regular assessment of:

- quality system
- product

PPSU Fittings

PRODUCT SPECIFICATION

PPSU press fittings according to BRL-K 536 part G: Plastics piping systems of PE-RT/Al intended for the transport of cold and heated drinking water.

The fittings are suitable for the pipe dimensions as indicated in the table below.

Nominal outside diameter (mm)	Wall thickness (mm)	Wall thickness aluminum layer (mm)
16	2.0	0.2
17	2.0	0.2
20	2.0	0.2
26	3.0	0.4
32	3.0	0.4
40	3.5	0.6
50	4.0	0.6

Colour of the fittings: grey

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017, published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.





The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The products are marked with the Kiwa-mark.

Fittings


The minimum required marking on the fittings shall be:

- **KIWA**  or on small products  or  or **KK*** or **KK*** (if not possible **KIWA**  only on the smallest packaging unit)**;
- manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe in mm;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clear, durable and indelible.

The smallest packaging unit of the fittings are provided with at least the following information:

- **KIWA** ;
- manufacturer's name, trade name, system name, logo or certificate number of the accompanying technical approval (system) certificate, in accordance with the marking of the connecting pipe;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm;
- material identification in case the fitting body is made of plastics.

Location of the marks: on every package.

The realization of the marks is as follows: clear, durable and indelible.

*) for small fittings marking with only KK is permitted

***) only after approval by Kiwa

PPSU Fittings

LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The piping system is intended to be used for the transport of cold and hot drinking water according to a temperature profile class 2 of ISO 10508 and an allowable working pressure of maximum 10 bar.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Roth Werke GmbH
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.