



# MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**MAFI-AMERICA, INC OF NEW YORK, NY**

300 E. 42ND STREET, ZIP CODE: 10017

®

Category:

Construction Materials - Flooring

Cert. Scheme:

VOC Emissions

Accredited  
Standards &  
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

\*Conforms  
With:

LEED v4.1 ID+C, BD+C  
(CHPS) 2019 Core Criteria 3.0 EQ C6.1.2  
Criteria of MAS Certified Green® Program  
TVOC Emissions at 14-days

low-emitting materials  
flooring systems  
low-emitting material  
0.5 mg/m<sup>3</sup> or less

Bracketed  
Products:

Flooring Products: Oak, Ash, Beech, Walnut, Larch\*, Douglas Fir, Fir,  
Swiss Stone Pine.

Flooring Treatments: Natural, Volcano, Coral, Fresco, Carving, Lye Treated\*, Tiger Oak

\*Product tested as representative exemplar of products listed above.

Test Date:

4/2/2020

Report No.: 2000338

Certificate No.: MAS2000338

valid April 2020 to April 2021

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017

3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope



Testing Cert. # 2925.01  
Product Cert. # 2925.02

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>